

JYOTHI WATER SAMPLES ANALYSIS REPORT- 10.AUGUST.22

SI NO	LOCATION	PH	TDS	TURBIDITY	RC
1	Boys Hostel	7.6	168	0.1	0.2
2	Girls Hostel	7.4	167	0.1	0.2
3	Purifier-Decinial hall	7.0	164	0.0	0.0
4	Cooler-ADM Block	7.0	164	0.0	0.0
5	Purifier-Civil passage	7.0	165	0.0	0.0
6	Purifier-MR passage	7.2	164	0.0	0.0

All the tested parameters are with in limit

[Signature]
22/08/22



[Signature]
D. Thomas Kalhany

[Signature]
22/08/22

[Signature]
Dr. JOSE P THERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

JYOTHI WATER SAMPLES ANALYSIS REPORT- 12. SEPTEMBER. 22

SI NO	LOCATION	PH	TDS	TURBIDITY	RC
1	Boys Hostel	7.3	112	0.1	0.2
2	Girls Hostel	7.2	114	0.1	0.2
3	Purifier-Civil passage	7.0	108	0.0	0.0
4	Purifier-MR passge.	7.0	103	0.0	0.0
5	Purifier-Decinial hall	7.0	108	0.0	0.0
6	Cooler-ADM Block.	7.0	106	0.0	0.0

All the tested parameters are with in limit


G. Monas Kalliasney

Cgr

M. G. Cyriac

Lab in charge

J. 201



2

Jose P Therattil

Dr. JOSE P THERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

JYOTHI WATER SAMPLES ANALYSIS REPORT- 10.OCTOBER.22

SI NO	LOCATION	PH	TDS	TURBIDITY	RC
1	Boys Hostel	7.1	150	0.1	0.2
2	Cooler-ADM Block	7.2	148	0.0	0.0
3	Purifier-ECE passage	7.0	145	0.0	0.0
4	Purifier-MR passage.	7.0	148	0.0	0.0
5	Purifier-Auditorium	7.0	146	0.0	0.0
6	Girls Hostel	7.0	152	0.1	0.2

All the tested parameters are within limit



Cg
M. G. Cynan
Lab in charge

P
12/10/22


D. M. P. K. K.

Jose
Dr. JOSE P. JERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

JYOTHI WATER SAMPLES ANALYSIS REPORT- 10 November 2022

SI NO	LOCATION	PH	TDS	TURBIDITY	RC
1	Boys Hostel	7.3	150	0.1	0.2
2	Cooler-ADM Block	7.2	148	0.1	0.0
3	Purifier-ECE passage	7.0	145	0.2	0.0
4	Purifier-MR passage.	7.2	148	0.0	0.0
5	Purifier-Auditorium	7.0	146	0.1	0.0
6	.Girls Hostel	7.2	152	0.1	0.2

All the tested parameters are within limit



Handwritten signature and date: 16/11/22

Handwritten signature: D. M. K. K. K.

Handwritten signature: Cgm
Handwritten signature: M. A. Cyriac
Handwritten signature: Lab in charge
Handwritten signature: J. Gerath

P. THERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531


JYOTHI WATER SAMPLES ANALYSIS REPORT- 12.DECEMBER.22

SI NO	LOCATION	PH	TDS	TURBIDITY	FC
1	Boys Hostel	7.1	154	0.0	0.2
2	Cooler-ADM Block	7.1	151	0.0	0.0
3	Purifier-ECE passage	7.0	152	0.0	0.0
4	Purifier-Near chapel.	7.0	151	0.0	0.0
5	Purifier-Auditorium	7.0	151	0.0	0.0
6	.Girls Hostel	7.2	153	0.0	0.2

All the tested parameters are with in limit

12/12/22

2. Momen Kabbir

Cg
m a. cyrac
Lab in charge

Dr. JOSE P THERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

Water Quality Test Results of Jyothi Engineering College

Dated 14.02.2023

Sl no	Location	pH	Turbidity	TDS	RC
1	Boys Hostel	7.4	0.0	184	0.2
2	Purifier – Decennial Hall	7.0	0.0	180	0
3	Purifier – Civil Passage	7.1	0.0	179	0
4	Water Cooler ADM block	7.3	0.0	178	0
5	Purifier ME passage	7.1	0.0	179	0
6	Ladies hostel	7.4	0.0	182	0.2

Cgn
Lab in charge


Water Quality Test Results of Jyothi Engineering College

Dated 14.02.2023

Sl no	Location	pH	Turbidity	TDS	RC
1	Boys Hostel	7.4	0.0	184	0.2
2	Purifier – Decennial Hall	7.0	0.0	180	0
3	Purifier – Civil Passage	7.1	0.0	179	0
4	Water Cooler ADM block	7.3	0.0	178	0
5	Purifier ME passage	7.1	0.0	179	0
6	Ladies hostel	7.4	0.0	182	0.2

Cgn
M. G. Cyril
Lab in charge

13/2/23



Dr. JOSE P THERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

Water Quality test Results of Jyothi Engineering College

Dated 13.03.2023

Sl no	Location	pH	Turbidity	TDS	RC
1	Boys Hostel	7.3	0.1	236	0.2
2	Purifier - Decennial Hall	7.1	0.0	230	0
3	Purifier - Civil Passage	7.1	0.0	232	0
4	Water Cooler ADM block	7.1	0.0	232	0
5	Purifier ME passage	7.1	0.0	231	0
6	Ladies hostel	7.2	0.1	234	0.2

All the tested parameters are within limit

[Handwritten signature]
17/3/23



[Handwritten signature]
M. A. Cynal
Lab in charge
[Handwritten signature]

DR. JOSE P. THERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

Water Quality test Results of Jyothi Engineering College

Dated 12.04.23

Sl no	location	pH	Turbidity	TDS	RC
1	Boys Hostel	7.3	0.0	250	0.2
2	Purifier - Decennial Hall	7.1	0.0	248	0
3	Water Cooler -ADM block	7.2	0.0	249	0
4	Filter EC passage	7.1	0.0	248	0
5	Purifier ME passage	7.1	0.0	247	0
6	Ladies hostel	7.2	0.0	249	0.2

All the tested parameters are within limit

Dr. Momen Kalliasrey



Dr. Momen Kalliasrey
Executive Manager

Cp

M. G. Cyrice
Lab in charge

Dr. JOSE P THEVARIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

Water Quality test Results of Jyothi Engineering College

Dated 12.05.2023

Sl no	Location	pH	Turbidity	TDS	RC
1	Boys Hostel	7.2	0.0	230	0.2
2	Purifier – Decennial Hall	7.3	0.0	228	0
3	Purifier – Civil Passage	7.0	0.0	228	0
4	Water Cooler ADM block	7.1	0.0	229	0
5	Purifier ME passage	7.0	0.0	230	0
6	Ladies hostel	7.1	0.0	228	0.2

All the tested parameters are within limit



Cgr

*M. S. Cyriac
Lab in charge*

I. Momen Kadhassan

Jeralal

Dr. JOSE P. IYERATTIL
Principal
Jyothi Engineering College
Cheruthuruthy - 679531

Water Quality test Results of Jyothi Engineering College

Dated 12.06.23

Sl no	location	pH	Turbidity	TDS	RC
1	Boys Hostel	7.3	0.0	230	0.2
2	Purifier - Decennial Hall	7.1	0.0	232	0
3	Water Cooler -ADM block	7.2	0.0	232	0
4	Filter EC passage	7.1	0.0	230	0
5	Purifier ME passage	7.1	0.0	230	0
6	Ladies hostel	7.2	0.0	232	0.2

All the tested parameters are within limit



Thomas Kaldenny
M. G. Cyriac
Lab in charge

Principal
Jyothi Engineering College
Cheruthuruthy - 679531